

Site Name	Streetname	Town	State	TestName	Frequency Months	Due Date
Albany Street Bus Garage	421 Albany Street	Boston	MA	MA TPI (3RD PARTY UST INSPECTION)	36	7/2022
				CONTAINMENT SUMP (STP) TEST	36	10/2022
				SPILL BUCKET TEST	36	9/2024
Cabot Yard Bus Garage	275 Dorchester Avenue	South Boston	MA	CONTAINMENT SUMP (DISP) TEST	36	10/2022
				MA TPI (3RD PARTY UST INSPECTION)	36	7/2022
				CONTAINMENT SUMP (STP) TEST	36	10/2022
				SPILL BUCKET TEST	36	5/2022
Cabot Yard Auto Garage	275 Dorchester Avenue	South Boston	MA	SPILL BUCKET TEST	36	11/2023
				MA TPI (3RD PARTY UST INSPECTION)	36	7/2022
				CONTAINMENT SUMP (STP) TEST	36	10/2022
Charlestown Bus Storage Garage	21 Arlington Avenue	Charlestown	MA	MA TPI (3RD PARTY UST INSPECTION)	36	7/2022
				CONTAINMENT SUMP (STP) TEST	36	10/2022
				SPILL BUCKET TEST	36	6/2023
Charlestown Truck Garage	26 Arlington Avenue	Charlestown	MA	SPILL BUCKET TEST	36	8/2022
				CONTAINMENT SUMP (DISP) TEST	36	10/2022
				MA TPI (3RD PARTY UST INSPECTION)	36	7/2022
				CONTAINMENT SUMP (STP) TEST	36	10/2022
Fellsway Bus Garage	465 Salem Street	Medford	MA	MA TPI (3RD PARTY UST INSPECTION)	36	7/2022
				CONTAINMENT SUMP (STP) TEST	36	10/2022
				SPILL BUCKET TEST	36	6/2023
Quincy Bus Garage	954 Hancock Street	Quincy	MA	SPILL BUCKET TEST	36	7/2022
				CONTAINMENT SUMP (STP) TEST	36	10/2022
				CONTAINMENT SUMP (DISP) TEST	36	10/2022
				MA TPI (3RD PARTY UST INSPECTION)	36	6/2023
Andrew Square Station	496 Southampton Street	South Boston	MA	SPILL BUCKET TEST	36	5/2022
				CONTAINMENT SUMP (PIPING) TEST	36	10/2022
				MA TPI (3RD PARTY UST INSPECTION)	36	7/2022
Quincy Adams Station	Burgin Parkway and Center Street	Quincy	MA	MA TPI (3RD PARTY UST INSPECTION)	36	7/2022
				SPILL BUCKET TEST	36	6/2023
				CONTAINMENT SUMP (PIPING) TEST	36	10/2022
South Boston Power Plant	696 E. 1st. Street	Boston	MA	MA TPI (3RD PARTY UST INSPECTION)	36	8/2022
				SPILL BUCKET TEST	36	6/2023
				CONTAINMENT SUMP (PIPING) TEST	36	10/2022
South Boston Power Plant	696 E. 1st. Street	Boston	MA	API 653 5 year In Service Inspection	60	9/2024
South Boston Power Plant	696 E. 1st. Street	Boston	MA	API 653 10 Year Out Of Service Inspection	120	9/2029